



APRAGAZ

a.s.b.l.
Your Inspection Authority



Chaussée de Vilvorde, 156 B-1120 Brussels
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

EUROFEU S.A.S.

12 rue Albert Rémy

FR - 28250 SENONCHES

Y/Ref. :
O/Ref. : CHL/BG

Brussels, 27 June 2019

APPROVAL CERTIFICATE EN 3 – PORTABLE FIRE EXTINGUISHERS

We hereby declare that the hereafter mentioned extinguishers were approved according to the requirements of the EN 3-7 standards and according to the hereafter mentioned tests reports:

Brand	Type	Nominal charge	Achieved fire ratings	EN 3-7 test report No.
EUROFEU	2 l AVD Lith. Ext.	2 l AVD.	5 A	EN 12053
EUROFEU	6 l AVD Lith. Ext.	6 l AVD.	13 A	EN 12054
EUROFEU	9 l AVD Lith. Ext.	9 l AVD	13 A	EN 12055

The General Manager,

Christian LEPLAT, ir.